



# Union Water Supply System

P.O. Box 340, 1615 Union Avenue, Ruthven, Ontario, N0P 2G0

Tele: 519-326-1668 Fax: 519-326-3490

Email: [rbouchard@unionwater.ca](mailto:rbouchard@unionwater.ca)

[www.unionwater.ca](http://www.unionwater.ca)

**SENT BY: EMAIL**

February 18, 2021

Town of Kingsville  
2021 Division Road North  
Kingsville, Ontario  
N9Y 2Y9

## **Attention: Mr. John Norton, Chief Administrative Officer**

Dear Mr. Norton,

**RE: Annual Report (2020) Requirement Section 11, Reg. 170/03 and Summary Report (2020) Requirement Schedule 22, Reg. 170/03**

Attached are the following items for the Kingsville Water Distribution System supplied by the UWSS:

1. Annual Report (Section 11, Reg. 170/03)
2. Summary Report (Schedule 22, Reg. 170/03).

### **Annual Report**

The Annual Report must be prepared before February 28, 2021 which requirement is now satisfied. It must also be provided to all members of Council, given at no charge to the public on request and posted on the municipal website.

### **Summary Report**

The Summary Report must be provided to all members of Council before March 31, 2021. Although the Report gives information for all parts of the UWSS, the information that refers to the Kingsville Water Distribution System satisfies the requirements of Schedule 22, Reg. 170/03.

Please call me if you have any questions or comments.

Yours truly,

A handwritten signature in blue ink, appearing to read 'R. Bouchard'.

Rodney Bouchard, Manager  
Union Water Supply System Joint Board of Management

kmj

CC: Andrew Plancke, Shaun Martinho

Filename: e:\khristine\annual-summary\2020\02-18-21 ltr to cao kingsville - annual - summary (2020).docx



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



## Annual Performance Report

**Kingsville Distribution System**

**Drinking Water System # 220003403**

**2020**

Prepared for the Corporation of the Town of Kingsville

By the Ontario Clean Water Agency  
Sam Wen  
Process & Compliance Technician  
[swen@ocwa.com](mailto:swen@ocwa.com)  
519-326-4447

## ANNUAL REPORT

Drinking Water System Number:	220003403
Drinking Water System Name:	Kingsville Distribution System (Union WSS)
Drinking Water System Owner:	The Corporation of The Town of Kingsville
Drinking Water System Category:	Large Municipal Residential
Period being reported:	01-January-2020 to 31-December 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking Water System serve more than 10,000 people? Yes [ <input checked="" type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ <input checked="" type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; width: fit-content;">           Town of Kingsville Municipal Office            2021 Division Rd. North,            Kingsville, Ontario         </div>	<p><b><u>Complete for all other Categories</u></b></p> <p>Number of Designated Facilities served: N/A</p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Number of Interested Authorities you report to: N/A</p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ]</p>
---	--

**Note:** For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report

**List all Drinking Water Systems (if any), which receive all their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all drinking water?  
 Yes [  ] No [  ] N/A

Indicate how you notified system users that your annual report is available and is free of charge.

Public access/notice via the web  
 Public access/notice via Government Office  
 Public access/notice via a newspaper  
 Public access/notice via Public Request  
 Public access/notice via a Public Library  
 Public access/notice via other method \_\_\_\_\_

#### Describe your Drinking Water System

**Distribution only. Water Distribution Class II serving approximately 22,000 people through approximately 7500 service connections fed from approximately 315 km of system infrastructure water main.**

List all water treatment chemicals used over this reporting period

N/A

Were any significant expenses incurred to?

Install required equipment  
 Repair required equipment  
 Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

In 2020, Kingsville incurred approximately \$5,600,000.00 in operational expenses and a further \$1,000,000.00 in Capital works projects required to maintain the water system.

Provide details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

	Number of Samples	Range of E. Coli Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	See annual report for the Union Water Supply System # 210000853				
Treated	See annual report for the Union Water Supply System # 210000853				

Distribution	467	0-0	0-0	208	<10 - <10
--------------	-----	-----	-----	-----	-----------

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	Please see the Annual Report for the Union Water Supply System # 210000853		
Chlorine	624	1.26-2.03	mg/L
Fluoride (If the DWS provides fluoridation)	N/A	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Nitrite (N)	07-Jan-2020	<0.1	mg/L	No
Nitrate (N)		0.5	mg/L	No
Ammonia N-Total		0.04	mg/L	No
Nitrite (N)	06-Apr-2020	<0.1	mg/L	No
Nitrate (N)		0.5	mg/L	No
Ammonia N-Total		0.08	mg/L	No
Nitrite (N)	07-July-2020	<0.1	mg/L	No
Nitrate (N)		0.4	mg/L	No
Ammonia N-Total		0.05	mg/L	No
Nitrite (N)	05-Oct-2020	<0.1	mg/L	No
Nitrate (N)		0.2	mg/L	No
Ammonia N-Total		0.06	mg/L	No

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	N/A	N/A	N/A	N/A
Distribution	24	0.1-3.56	ug/L	No

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>THM</b> (NOTE: show latest annual average)	Annual Average	29.75	ug/L	No
<b>HAA</b> (NOTE: show latest annual average)	Annual Average	15.45	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards

Parameter	Result Value	Unit of Measure	Date of Sample
<b>None</b>			

# UNION WATER SUPPLY SYSTEM SUMMARY REPORT 2020

For the Union Water Supply System  
(Made under Schedule 22 of Ontario Regulation 170/03, a regulation made under  
the Safe Drinking Water Act, 2002)

## EXPLANATION

Schedule 22 of Ontario Regulation 170/03, a regulation made under the Safe Drinking Water Act, 2002 requires that a large municipal residential drinking-water system that is owned by a municipality, municipal board or municipal corporation must provide to its councillors or board members a Summary Report on various aspects of the system before March 31 of the following year. The Union Water Supply System is classed as a large municipal residential drinking-water system and is therefore subject to Schedule 22.

The Summary Report must list the following:

- Any requirements of the Safe Drinking Water Act, 2002 that the system failed to meet during the period covered by the Summary Report
- Any requirements of the regulations made under the Safe Drinking Water Act, 2002 that the system failed to meet during the period covered by the Summary Report
- Any condition of the drinking-water system's drinking water works permit or municipal drinking water license that the system failed to meet during the period covered by the Summary Report
- Any order that the system failed to meet during the period covered by the Summary Report, the duration of any such failure and any measures that were taken to correct such failure
- A summary of the quantities and flow rates of water supplied by the drinking-water system by monthly average and maximum daily flow rates and instantaneous peak flow rates
- A comparison of actual flow rates with rated capacity and flow rates in the system's approval

A drinking-water system that supplies water to another drinking water system must provide a copy of the Summary Report to that system's owner by March 31 of the year following the year covered in the Summary Report.

The sections below details the occasions on which the Union Water Supply System (UWSS) and the connected municipal water systems failed to meet the requirements of the Safe Drinking Water Act 2002, associated regulations, system approvals and provincial officer orders in 2020.

## Union Water Supply System (UWSS)

The following provides details of occurrences where the Union Water Supply System was not in compliance with the requirements of the Safe Drinking Water Act 2002, associated regulations, system approvals and provincial officer orders.

***Non-Compliance Item:***

There were no non-compliances or Adverse Water Quality Incidents (AWQIs) identified for the portion of the Union Water common Distribution System that is supplied by Union Water Supply System.

**Leamington Water Distribution System**

***Non-Compliance Item:***

The following Adverse Water Quality Incident (AWQI) identified for the Leamington Distribution System that is supplied by the Union Water Supply System.

- AWQI #150851 on July 21, 2020 - sample taken at distribution station SS-L-14 with a TC count of 5. A BWA was issued on July 21, 2020. Staff flushed and resampled the affected area upstream and downstream on July 22, 2020 and 24 hours later. Those samples were returned clean.

**Kingsville Water Distribution System**

***Non-Compliance Item:***

There were no non-compliances or Adverse Water Quality Incidents (AWQIs) identified for the portion of the Kingsville Distribution System that is supplied by the Union Water Supply System.

**Essex Water Distribution System**

***Non-Compliance Item:***

There were no non-compliances or Adverse Water Quality Incidents (AWQIs) identified for the portion of the Essex Distribution System that is supplied by the Union Water Supply System.

**Lakeshore Water Distribution System**

***Non-Compliance Item:***

There were no non-compliances or Adverse Water Quality Incidents (AWQIs) identified for the portion of the Lakeshore Distribution System that is supplied by the Union Water Supply System

**SUMMARY OF THE QUANTITIES AND FLOW RATES OF WATER SUPPLIED DURING THE PERIOD COVERED BY THE REPORT, INCLUDING MONTHLY AVERAGE AND MAXIMUM DAILY FLOWS, AND DAILY INSTANTANEOUS PEAK FLOW RATES**

The following sections provide information in regards to the Union Water Supply System's Permit to Take Water, issued under Ontario Regulation 387/04 and Drinking Water License issued under the Safe Drinking Water Act, 2002.

## **Permit to Take Water**

The Union Water Supply System operated under Permit to Take Water (PTTW) Number 0816-9T9SVT, which expires at the end of 2025. The PTTW has the following flow conditions:

- Maximum Allowable Amount Taken per Minute (Litres/Min) 113,650
- Maximum Allowable Amount Taken Per Day (Litres/Day) 163,656,000

The maximum amounts of raw water taken during 2020 (see Table 1 below) are as follows:

- Maximum Amount Taken per Minute in 2020 (Litres/Min) 88,304
- Maximum Amount Taken Per Day in 2020 (Litres/Day) 109,548,000

The system did not exceed the PTTW limits in 2020.

## **Drinking Water License**

The UWSS operates under Municipal Drinking Water Licence 041-101; issue Number 7 which has been issued for the period July 18, 2020 to July 17, 2024. The Certificate of Approval and licence had the following condition:

- The drinking water system shall not be operated to exceed 124,588 m<sup>3</sup>/d (27.4 MIGD) on any calendar day, conveyed from the treatment system to the distribution system.
- The maximum daily volume of water pumped into the distribution system was 97,115m<sup>3</sup> (21.37 MIGD).

Tables 1A through 3B below provide the monthly average, maximum and peak flows for raw and treated water for the Union Water Supply System.

**Table 1A**  
**2020 Raw Water Taking from Lake Erie in Metric Units**

	Maximum Allowed Flow Rate (m <sup>3</sup> /Day)	Average Flow (m <sup>3</sup> /Day)	Maximum Flow (m <sup>3</sup> /Day)	Maximum Flow (Litres/Day)	Maximum Allowed Flow Rate (Litres/Minute)	Peak Flow (Litres/Minute)
January	163,656	37,015	53,328	53,328,000	113,650	39,327
February	163,656	49,162	61,784	61,784,000	113,650	54,153
March	163,656	49,790	62,419	62,419,000	113,650	56,430
April	163,656	56,648	72,729	72,729,000	113,650	68,639
May	163,656	65,811	89,261	89,261,000	113,650	70,877
June	163,656	87,655	102,430	102,430,000	113,650	88,304
July	163,656	89,066	109,548	109,548,000	113,650	85,443
August	163,656	80,258	95,148	95,148,000	113,650	81,234
September	163,656	70,016	83,782	83,782,000	113,650	65,909
October	163,656	53,097	70,882	70,882,000	113,650	57,231
November	163,656	45,276	55,625	55,625,000	113,650	44,825
December	163,656	39,059	50,225	50,225,000	113,650	38,658

**Table 1B**  
**2020 Raw Water Taking from Lake Erie in Imperial Units**

	Maximum Allowed Flow Rate (MGD)	Average Flow (MGD)	Maximum Flow (MGD)	Maximum Allowed Flow Rate (Gallons/Minute)	Peak Flow (Gallons/Minute)
January	36.00	8.14	11.73	25,000	8,651
February	36.00	10.81	13.59	25,000	11,912
March	36.00	10.95	13.73	25,000	12,413
April	36.00	12.46	16.00	25,000	15,098
May	36.00	14.48	19.63	25,000	15,591
June	36.00	19.28	22.53	25,000	19,424
July	36.00	19.59	24.10	25,000	18,795
August	36.00	17.65	20.93	25,000	17,869
September	36.00	15.40	18.43	25,000	14,498
October	36.00	11.68	15.59	25,000	12,589
November	36.00	9.96	12.24	25,000	9,860
December	36.00	8.59	11.05	25,000	8,504

**Table 2A**  
**2020 Treated Water Flow Into Distribution System in Metric Units**

	Maximum Allowed Flow Rate (m3/Day)	Average Daily Flow (m3/Day)	Maximum Daily Flow (m3/Day)	Peak Instantaneous Flow (Litres/Second)
January	124,588	30,367	34,881	692
February	124,588	35,813	43,409	991
March	124,588	40,043	51,603	1,281
April	124,588	48,283	60,293	1,415
May	124,588	57,150	80,559	1,432
June	124,588	78,083	94,982	1,680
July	124,588	79,103	97,115	1,668
August	124,588	71,457	86,082	1,574
September	124,588	61,282	75,349	1,384
October	124,588	46,019	62,831	1,265
November	124,588	39,226	46,742	1,247
December	124,588	33,815	42,260	740

**Table 2B**  
**2020 Treated Water Flow Into Distribution System in Imperial Units**

	Maximum Allowed Flow Rate (MGD)	Average Daily Flow (MGD)	Maximum Daily Flow (MGD)	Peak Instantaneous Flow (Gallons/Second)
January	27.4	6.68	7.67	152
February	27.4	7.88	9.55	218
March	27.4	8.81	11.35	282
April	27.4	10.62	13.26	311
May	27.4	12.57	17.72	315
June	27.4	17.18	20.90	370
July	27.4	17.40	21.37	367
August	27.4	15.72	18.94	346
September	27.4	13.48	16.58	304
October	27.4	10.12	13.82	278
November	27.4	8.63	10.28	274
December	27.4	7.44	9.30	163

**Table 3A**  
**2020 Treated Flow to Local Municipalities in Metric Units**

	<i>Leamington</i>		<i>Kingsville</i>		<i>Essex</i>		<i>Lakeshore</i>	
	Monthly Total (m3)	Average Day (m3/day)						
<b>January</b>	475,832	15,349	334,112	10,778	60,333	1,946	64,841	2,092
<b>February</b>	545,669	18,816	375,337	12,943	58,335	2,012	47,709	1,645
<b>March</b>	685,087	22,100	484,097	15,616	64,133	2,069	53,252	1,718
<b>April</b>	790,081	26,336	567,939	18,931	60,936	2,031	50,449	1,682
<b>May</b>	908,541	29,308	616,542	19,888	67,187	2,167	54,170	1,747
<b>June</b>	1,313,910	43,797	958,039	31,935	112,973	3,766	74,235	2,475
<b>July</b>	1,358,244	43,814	942,699	30,410	95,680	3,086	69,744	2,250
<b>August</b>	1,237,242	39,911	884,356	28,528	93,561	3,018	68,871	2,222
<b>September</b>	1,019,718	33,991	706,956	23,565	75,854	2,528	61,189	2,040
<b>October</b>	788,481	25,435	472,507	15,242	72,606	2,342	61,197	1,974
<b>November</b>	677,214	22,574	363,478	12,116	62,862	2,095	64,841	2,161
<b>December</b>	549,454	17,724	373,269	12,041	61,576	1,986	64,483	2,080
<b>Total</b>	<b>10,349,473</b>	<b>28,263</b>	<b>7,079,331</b>	<b>19,333</b>	<b>886,036</b>	<b>2,421</b>	<b>734,981</b>	<b>2,007</b>

**Table 3A**  
**2020 Treated Flow to Local Municipalities in Imperial Units**

	<i>Leamington</i>		<i>Kingsville</i>		<i>Essex</i>		<i>Lakeshore</i>	
	Monthly Total (Imperial Gallons)	Average Day (MGD)						
<b>January</b>	104,668,407	3.38	73,494,365	2.37	13,271,405	0.43	14,263,026	0.46
<b>February</b>	120,030,400	4.14	82,562,598	2.85	12,831,906	0.44	10,494,513	0.36
<b>March</b>	150,698,072	4.86	106,486,453	3.44	14,107,288	0.46	11,713,802	0.38
<b>April</b>	173,793,524	5.79	124,929,115	4.16	13,404,046	0.45	11,097,229	0.37
<b>May</b>	199,851,081	6.45	135,620,280	4.37	14,779,074	0.48	11,915,734	0.38
<b>June</b>	289,019,795	9.63	210,739,119	7.02	24,850,586	0.83	16,329,417	0.54
<b>July</b>	298,771,912	9.64	207,364,790	6.69	21,046,658	0.68	15,341,535	0.49
<b>August</b>	272,155,193	8.78	194,531,125	6.28	20,580,543	0.66	15,149,502	0.49
<b>September</b>	224,306,602	7.48	155,508,580	5.18	16,685,547	0.56	13,459,698	0.45
<b>October</b>	173,441,573	5.59	103,937,010	3.35	15,971,087	0.52	13,461,458	0.43
<b>November</b>	148,966,255	4.97	79,953,982	2.67	13,827,707	0.46	14,263,026	0.48
<b>December</b>	120,862,983	3.90	82,107,701	2.65	13,544,826	0.44	14,184,277	0.46
<b>Total</b>	<b>2,276,565,796</b>	<b>6.22</b>	<b>1,557,235,119</b>	<b>4.25</b>	<b>194,900,673</b>	<b>0.53</b>	<b>161,673,218</b>	<b>0.44</b>